

# APPENDIX TO PFE CERTIFICATION LICENCE

## Particulars of Product

Product name / type:	<b>T12</b>
Identification no:	<b>500-003</b>
Fire classification:	<b>55A, 233B</b>
Temperature range:	<b>-30 - +60 °C</b>
Extinguishing medium:	<b>Powder, Furex ABC 40 Blue</b>
Charge volume:	<b>12 Kg</b>

## Drawings

Manufactured according to the following main drawings:  
Fire Extinguisher: 13172 dated 08.05.2003 from a.b.s. S.r.l.  
Pressure vessel: 27503 dated 29.10.2004 from a.b.s. S.r.l.  
Discharge valve: 21821 dated 09.12.2002 from a.b.s. S.r.l.

## Test report(s)

EN 3-7: Test report No. 3648-2005 dated 11 October 2005 from Istituto Di Ricerche E Collaudi M. Masini S.r.l. Italy.  
EN 3-8: Test report No. 20140532/ABS 08 dated 7 May 2014 from MPA Dresden GmbH, Germany.

## Marking



Marking according to DNV GL-ST-0371 Section 4.  
Identification no. to be placed below the certification mark.

## Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **28-02-2018**

for **DNV GL**

**Synnøve Bolstad Eri**  
**Approval Engineer**

For use of the certification mark, please refer to the guidelines provided with the mark.