

APPENDIX TO PFE CERTIFICATION LICENCE

Particulars of Product

Product name / type:	S6F
Identification no:	500-005
Fire classification:	34A, 233B, 75F
Temperature range:	-30 - +60 °C
Extinguishing medium:	Sealfire AB-30
Charge volume:	6 L

Drawings

Manufactured according to the following main drawings:
Fire Extinguisher: 13366 dated 21.04.2009 from a.b.s. S.r.l.
Pressure vessel: 27618-1 dated 21.04.2009 from a.b.s. S.r.l.
Discharge valve: 21815-1 dated 23.06.2009 from a.b.s. S.r.l.

Test report(s)

EN 3-7: Test report No.2281-2009 dated 25 November 2009 from Istituto Di Ricerche E Collaudi M. Masini S.r.l. Italy.
EN 3-8: Test report No. 20151713/ABS 25 dated 4 February 2016 from MPA Dresden GmbH, Germany.

Marking



Marking according to DNV GL-ST-0371 Section 4.
Identification no. to be placed below the certification mark.

Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **28-02-2018**

for **DNV GL**

Synnøve Bolstad Eri
Approval Engineer

For use of the certification mark, please refer to the guidelines provided with the mark.