

APPENDIX TO PFE CERTIFICATION LICENCE

Particulars of Product

Product name / type:	MUTNOS S6 Extra
Identification no:	500-009
Fire classification:	43A, 233B, 75F
Temperature range:	0 - +60 °C
Extinguishing medium:	Foam, Sealfire ABF
Charge volume:	6 L

Drawings

Manufactured according to the following main drawings:
Fire Extinguisher: 13363_45 dated 07.02.2013 from a.b.s S.r.l.
Pressure vessel: 27613_45 dated 07.02.2013 from a.b.s S.r.l.
Discharge valve: 21815_1 dated 23.06.2009 from a.b.s S.r.l.

Test report(s)

EN 3-7: CSI/011/13/LEP/Rev.1 dated 27 November 2013 from CSI Spa Certificazione & Testing, Bollate(MI), Italy.
EN 3-8: Test report No. 2013-F-4536/ABS 02 dated 7 November 2013 from MPA Dresden GmbH, Germany.

Marking



Marking according to DNV GL-ST-0371 Section 4.
Identification no. to be placed below the certification mark.

Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **28-02-2018**

for **DNV GL**

Synnøve Bolstad Eri
Approval Engineer

For use of the certification mark, please refer to the guidelines provided with the mark.