

# APPENDIX TO PFE CERTIFICATION LICENCE

## Particulars of Product

Product name / type:	<b>PS2-P ABC</b>
Identification no:	<b>650-001</b>
Fire classification:	<b>13A, 89B</b>
Temperature range:	<b>-30 - +60 °C</b>
Extinguishing medium:	<b>Powder, A33/ABC</b>
Charge volume:	<b>2 kg</b>

## Drawings

Manufactured according to the following main drawings:  
Fire extinguisher: 33.659B.F000.00 Rev.A from ANAF Group dated 2014-04-01  
Pressure vessel: 00.654B.7895.CE Rev.D from ANAF Group dated 2017-07-06

## Test report(s)

EN 3-7: Report No. EN 11391 from Apragaz dated 2014-07-14  
EN 3-8: Report No. EN 11870 from Apragaz dated 2017-09-27  
Statement Ref. CHL/MMO for type PS2-P from Apragaz dated 2018-07-11

## Marking



Marking according to DNV GL-ST-0371 Section 4.  
Identification no. to be placed below the certification mark.

## Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **2018-07-12**

for **DNV GL**

**Synnøve Bolstad Eri**  
**Approval Engineer**

For use of the certification mark, please refer to the guidelines provided with the mark.