

# APPENDIX TO PFE CERTIFICATION LICENCE

## Particulars of Product

Product name / type:	<b>PS6-HJ ABC</b>
Identification no:	<b>650-002</b>
Fire classification:	<b>43 A, 233 B</b>
Temperature range:	<b>-30 - +60A °C</b>
Extinguishing medium:	<b>ABC fire extinguishing powder TOP</b>
Charge volume:	<b>6 kg</b>

## Drawings

Manufactured according to the following main drawings:  
Fire extinguisher: 83.890E.F000.00 Rev. A from ANAF Group dated 2018-01-16  
Pressure vessel: 00.490E.7895.CE Rev.B from ANAF Group dated 2018-03-16

## Test report(s)

EN 3-7: Report No. EN 11292 from Apragaz dated 2013-05-24  
Report No. 20171648/AN 99 from MPA Dresden dated 2018-03-06 (supplementary for TOP powder)  
Report No. 2013-F-3054/AN 69 from MPA Dresden dated 2013-06-28 (supplementary from MPA Dresden)  
EN 3-8: Report No. EN 11944 from Apragaz dated 2018-03-26  
Statement Ref. CHL/MMO for type PS6-HJ from Apragaz dated 2018-07-11

## Marking



Marking according to DNV GL-ST-0371 Section 4.  
Identification no. to be placed below the certification mark.

## Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **2018-07-12**

for **DNV GL**

**Synnøve Bolstad Eri**  
**Approval Engineer**

For use of the certification mark, please refer to the guidelines provided with the mark.