

# APPENDIX TO PFE CERTIFICATION LICENCE

## Particulars of Product

Product name / type:	<b>FS6-J</b>
Identification no:	<b>650-003</b>
Fire classification:	<b>27A, 233B</b>
Temperature range:	<b>0 - 60 °C</b>
Extinguishing medium:	<b>4.98L water + 0.9L Solrik A + 0.12L Capstone 1430</b>
Charge volume:	<b>6L</b>

## Drawings

Manufactured according to the following main drawings:  
Fire extinguisher: 09.860E.F000.00 Rev. C from ANAF Group dated 2015-07-20  
Pressure vessel: 00.855E.7895CE Rev. B from ANAF Group dated 2017-09-14

## Test report(s)

EN 3-7: Report No. 10633 from Apragaz dated 2006-09-25  
Report No. 10633-1 from Apragaz dated 2010-08-02 (supplementary for plastic foot)  
Report No. 10633-2 from Apragaz dated 2016-07-06 (supplementary for extinguishing medium)  
EN 3-8: Report No. 11911 from Apragaz dated 2017-11-30  
Statement Ref. CHL/MMO for type FS6-J from Apragaz dated 2018-07-11

## Marking



Marking according to DNV GL-ST-0371 Section 4.  
Identification no. to be placed below the certification mark.

## Notes

In order to maintain the validity of the licence the licensee is obliged to inform DNV GL about any changes in the information given in this Appendix.

Place: **Høvik, Norway** Date: **2018-07-12**

for **DNV GL**

**Synnøve Bolstad Eri**  
**Approval Engineer**

For use of the certification mark, please refer to the guidelines provided with the mark.